



HIGH LEVEL ALARM

The High Level Alarms are designed to provide warning indication when the pump tank is full.

The buzzer can be muted via a mute button. If not muted the audible buzzer will automatically silence after 5 minutes. If a continuously sounding audible alarm is required, this can be done by changing the jumper position on the circuit board. Both the audible and visual alarm will run for up to 6 hours.

The visual alarms will continue to remain on, until the alarm condition is resolved. A standard feature of the Level Alarm is a 'Voltage Free' (5 amp rated) output for connection to auxiliary devices.

Controller can be installed near the pump tank. Float switch cabling is 'safe', low voltage circuitry.

Warning indication is determined by a float switch. Warnings are Audio (buzzer) and Visual (LED Pilot Light and / or Strobe)

FEATURES & BENEFITS

Safe 12V low voltage cabling on float switch

Mute button to silence alarm

IP55 enclosure for outdoor installation

Audible Alarm sound level is 90dB



2 x Single Weatherproof GPO's 10amps to be installed by a licenced electrician on post provided by Filtrex near location of pump tank installation. GPO's require to be on separate circuits.

- 1 x GPO for operation of audio visual alarm
- 1 x GPO for operation of sump pump

Cabling is left so electrician can installing conduit and connect into the GPO's.

